

DECLARATION



17 September 2014

Blower-Door-Test EM-Flex weather seals

BuildingLabel has performed in an objective manner a Blower-Door-Test on a standard dock leveler with and without EM-Flex weather seals. The results of this airtightness test clearly show that EM-Flex weather seals decrease the unwanted air flow with 94%.


This test is reproducible and suitable on all kind of dock levelers.

BuildingLabel.com B.V.
M.L. Lavèn
managing director



Test results

Pressure difference	50 Pa
Standard dock leveler	2246 m³/h
EM-Flex installed	145 m³/h
Difference	94% decrease



EM-FLEX
UNIVERSAL WEATHERSEALS

